



TOWN OF FUNKSTOWN, MD
UTILITIES DEPARTMENT
WATER DIVISION
301-791-0948
PWSID# 0210008
2015
WATER QUALITY DATA TABLE

Contaminant (units)	MCLG	MCL	Level		Violation	Typical Sources of Contaminants
			Found @ Funkstown	Range of Detection		
Haloacetic Acids (HAA5) (ppb/yr.avg.)	0	60	23.4	12.6-46.5	no	By-products of drinking water disinfection process
Trihalomethanes (TTHM) (ppb/yr.avg.)	0	80	33	23.7-114.2	no	By-products of drinking water disinfection process